

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **47 994 - 03 HH**

Company **Siemens AG Österreich
SIMEA IA SE
Siemensstr. 90-92
1210 Wien, AUSTRIA**

Product Description **Power supply**

Type **LOGO!Power 6EP13..; ..11-1SH02, ..21-1SH02, ..51-1SH02, ..31-1SH02,..11-1SH12, ..22-1SH02, ..52-1SH02, ..32-1SH42, (...31-1SH02-0AA0, ...32-1SH42-0AA0), continued on page 2**

Environmental Category **C, EMC2(30W-Serie),EMC1(60W)**

Technical Data / Range of Application **Rated input voltage Ue 100 - 240 V AC**

Type Ia	Rated output voltage Ua	Rated output current
6EP1311-1SH02	5 V DC	3 A
6EP1321-1SH02	12 V DC	1,9 A
6EP1351-1SH02	15 V DC	1,85 A
6EP1331-1SH02 (6EP1331-1SH02-0AA0)	24 V DC	1,3 A
6EP1311-1SH12	5 V DC	6,3 A
6EP1322-1SH02	12 V DC	4,5 A
6EP1352-1SH02	15 V DC	4 A
6EP1332-1SH42 (6EP1332-1SH42-0AA0)	24 V DC	2,5 A

continued on page 2

Degree of protection : IP 20

Test Standard **Regulations for the Performance of Type Tests, edition 2003**

Documents **Typprüfbericht LOGO!PowerII 60W *.doc, Typprüfbericht LOGO!PowerII 30W *.doc
Operating instr.: C98130-A7560-A1-03-6419.pdf, C98130-A7561-A1-04-6419.pdf
Drawings: C98130-A7561-X00(1),(2),(3),(4)-03-0005.pdf
C98130-A7560-X00(1),(2),(3)**

Remarks **None**

Valid until **2016-12-31**

Page **1 of 2**

File No. **I.M.03**

Hamburg, 2016-04-13

Type Approval Symbol



TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **47 994 - 03 HH**

continued from page 1

Type	Rated output voltage U _a	Rated output current I _a
6EP1311-1SH03	5 V DC	3 A
6EP1321-1SH03	12 V DC	1,9 A
6EP1351-1SH03	15 V DC	1,9 A
6EP1331-1SH03	24 V DC	1,3 A
6EP1311-1SH13	5 V DC	6,3 A
6EP1322-1SH03	12 V DC	4,5 A
6EP1352-1SH03	15 V DC	4 A
6EP1332-1SH43	24 V DC	2,5 A

Documents:

C98130-A7610-A001-01-7419, C98130-A7611-A001-01-7419, C98130-A7613-A001-01-7419, C98130-A7612-A001-01-7419

Degree of protection : IP 20

Valid until **2016-12-31**

Page **2 of 2**

File No. **I.M.03**

Hamburg, 2016-04-13

Type Approval Symbol

