## Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	12 155 - 98 HH
Company	Siemens AG I IA CE Werner-von-Siemens-Str. 48 92229 Amberg, GERMANY
Product Description	Contactors, Contactor Relays, Load Feeders
Туре	SIRIUS 3RT1 / 3RT19, 3RH11 / 3RH19, 3RA1 / 3RA19
Environmental Category	C
Technical Data / Range of Application	3RT1 - contactor rated power (690V): AC-2, AC-3: 4kW up to500kW, AC1 up to 783kW coil voltage: 12-250 V dc / 24-600V 50 / 60 Hz ac / 21-600 V ac/dc 3RT19 - accessories surge suppressors / solid-state time relay blocks 3RH11, 3RH12, 3RH13, 3RH14 - contactor relays rated current: AC-15: 6 A / 230 V, DC-13: 0,25 A / 220 V coil voltage: 12-250 V dc / 24-600 V 50 / 60 Hz ac 3RH19 - accessories auxiliary switch blocks: AC-15: 6 A / 230 V, DC-13: 0,25 A / 220 V interface: AC-15: 3 A / 230 V, DC-13: 0,1 A / 220 V 3RA1, 3RA5 - load feeder direct-on-line starter - fuseless, size S00 / S0 / S2 / S3 reversing contactor - fuseless, size S00 / S0 / S2 / S3 3RA19 - accessories fixing and wiring kits / mechanical interlock
Test Standard	Guidelines for the Performance of Type Tests, Edition 2003, IEC - 947-4-1 (1990), Am. 1 (1994), Am. 2 (1996), IEC947-5-1 (1997) Am.1+2 (1999), IEC9471 (1999)
Documents	Siemens Report: Equipment under Test SIRIUS 3R, issued September 1997 including attachements, Amendment 02 issued September 2001
Remarks	None
Valid until	2017-07-29
Page 1 of 1	Type Approval Symbol <b>(GL</b> )
File No. I.K.03 Hamburg, 2012-07-30	ATA Mader
Germanischer l	Loyd Thomas Hartmann Harald Amberger
	s of "Guidalines for the Parformance of Type Approvals Part 1. Precedura"