

Type Approval Certificate



This is to certify that the undemoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	12 156 - 98 HH
Company	Siemens AG IA CE Werner-von-Siemens-Str. 48 92229 Amberg, GERMANY
Product Description	Overload Relays, thermal
Type	SIRIUS 3RU11 / 3RU19
Environmental Category	C, EMC1
Technical Data / Range of Application	3RU11 - overload relays rated power : 0,06-5,5 kW / 0,75-11 kW / 3-22 kW / 11-45 kW setting currents: 0,11-12 A / 1,8-25 A / 5,5-50 A / 18-100 A setting ranges: 20 / 12 / 10 / 8 3RU19 - accessories remote reset: 24-30 V ac,dc / 110-127 V ac,dc / 220-250 V ac,dc module for installation as single unit
Test Standard	Regulations for the Performance of Type Tests (2001), IEC947-5-1 (11-2003) EN 60947-4-1 (11-2000), IEC 60947-4-1 (2.2001)
Documents	Equipment under Test SIRIUS 3R, issued September 1997 including attachements, Siemens test reports:2235, 2237, 2239,2246, 2248
Remarks	None


Valid until 2019-05-04
Page 1 of 1
File No. I.L.02
Hamburg, 2014-05-05

Type Approval Symbol



Germanischer Lloyd


Arne Schaarmann


Harald Amberger

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure"