

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 46 461 - 12 HH

Company Mersen France SB S.A.S.
15 Rue Vaucanson
69720 Saint Bonnet de Mure, FRANCE

Product Description Fuse links aM, gG

Type FR10, FR14, FR22

Environmental Category C

Technical Data / Range of Application Ferrule fuse-links for fuse system F with or without striker, with or without indicator
Rated breaking capacity: 120kA

Fuse link ratings 10x38 for:	aM	gG
- rated operational Voltage 400 V AC:	25 -32 A	32 A
- rated operational Voltage 500 V AC:	0.16-20 A	0.5 A-25 A
- rated operational Voltage 690 V AC:	1-12 A	1-16 A

Fuse link ratings 14x51 aM/gG for:		
- rated operational Voltage 500 V AC:	1-50 A	2-50 A
- rated operational Voltage 690 V AC:	0.25-40 A	1-50 A

Fuse link ratings 22x58 aM/ gG for:		
- rated operational Voltage 500 V AC:	63-125 A	63-125 A
- rated operational Voltage 690 V AC:	1-80 A	2-80 A

Test Standard Guidelines for the Performance of Type Approvals Chapter 2, Edition 2003; IEC 60269 - 1 Ed.4 2006-11; IEC 60269 - 2 Ed. 3 2006-11

Documents Test report summary 2012-07-20 by Mersen, Synthetic description of fuse ranges (BTH,2011-06-24)

Remarks None

Valid until 2017-08-12

Page 1 of 1

File No. I.L.08

Hamburg, 2012-08-13

Type Approval Symbol



Germanischer Lloyd

Wolfgang Voß


Thomas Hartmann