DNV-GL

TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.

69 280 - 90 HH

Company

Rittal GmbH & Co. KG

Auf dem Stützelberg 35745 Herborn, GERMANY

Product Description

Cabinets

Type

Serial KL, AE,

Environmental Category

A

Technical Data / Range of Application Material: Steel or stainless steel

Degree of protection: IP66 (AE with single door, KL without gland plate)
IP55 (AE with double door, KL with gland plate)

Test Standard

Requirements for Electrical / Electronic Equipment and Systems (VI-7-2),

Edition 2012, IEC 62208, 2011

Documents

Test report: Rittal 1206/13 and 174/14

Remarks

This certificate is issued on the basis of GL Guidelines for the Performance of

Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007.

Valid until

2019-11-21

Page

1 of 1

File No.

I.J.02

Hamburg, 2014-11-26

Type Approval Symbol



Nolfgang Voß

Jens Altmann

DNV GL