

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. **98 789 - 96 HH**

Company **Mersen France SB S.A.S.**
15 Rue Vaucanson
69720 Saint Bonnet de Mure, FRANCE

Product Description **NH - fuse system**

Type **NH fuse-links sizes 000, 00, 1, 2, 3**
1B1xx; 1F1xx; 1B2xx; 1F2xx; 1B3xx; 1F3xx; 1B6xx; 1F6xx; 1B7xx; 1F7xx

Environmental Category **C**

Technical Data /
Range of Application **NH fuse-links sizes 000, 00, 1, 2, 3 with insulated and non-insulated gripping lugs**

Rated voltage U: **500 V AC**
Rated current I: **2 A to 630 A**
Rated frequency f: **45 to 62 Hz**
Rated breaking capacity I: **120 kA**
Utilization category: **gG**

Test Standard **IEC 60269-2-1(ed. 4.0); IEC 60269-1 (ed. 3.0)**

Documents **VDE CB test certificates:**
DE 1- 32350; DE 1- 32369; DE 1- 32371; DE 1- 32372; DE 1- 32373

Remarks **fuse links with non-insulated gripping lugs must be covered**

Valid until **2016-05-08**

Page **1 of 1**


Type Approval Symbol



File No. **I.L.08**

Hamburg, 2011-05-09

Germanischer Lloyd


Christoph Kutzner


Thomas Hartmann