## 6EP3330-6SB00-0AY0

**Data sheet** 



LOGO!Power/1AC/24VDC/0.6A

LOGO! Power 24 V / 0.6 A stabilized power supply input: 100-240 V AC output: 24 V DC/ 0.6 A \*Ex approval no longer available\*

input	
type of the power supply network	1-phase AC or DC
supply voltage at AC minimum rated value	100 240 V
supply voltage at AC maximum rated value	
supply voltage at AC initial value	85 264 V
supply voltage at AC full-scale value	
input voltage at DC	110 300 V
wide range input	Yes
overvoltage overload capability	300 V AC for 1 s
buffering time for rated value of the output current in the event of power failure minimum	40 ms
operating condition of the mains buffering	at Vin = 187 V
line frequency	50/60 Hz
line frequency initial value	47 63 Hz
line frequency full-scale value	
input current	
at rated input voltage 120 V	0.3 A
at rated input voltage 230 V	0.2 A
current limitation of inrush current at 25 °C maximum	20 A
I2t value maximum	0.8 A²-s
fuse protection type	internal
fuse protection type in the feeder	Recommended miniature circuit breaker: from 6 A characteristic B or from 2 A characteristic C
output	
voltage curve at output	Controlled, isolated DC voltage
output voltage at DC rated value	24 V
output voltage	
at output 1 at DC rated value	24 V
output voltage adjustable	No
relative overall tolerance of the voltage	3 %
relative control precision of the output voltage	
<ul> <li>on slow fluctuation of input voltage</li> </ul>	0.1 %
<ul> <li>on slow fluctuation of ohm loading</li> </ul>	0.1 %
residual ripple	
• maximum	200 mV
• typical	30 mV
voltage peak	
• maximum	300 mV
• typical	50 mV
display version for normal operation	Green LED for output voltage OK

habanian of the authority of the security to	No everyland of Veryl (author-t)
behavior of the output voltage when switching on	No overshoot of Vout (soft start)
response delay maximum	0.5 s
voltage increase time of the output voltage	
• typical	100 ms
output current	
rated value	0.6 A
rated range	0 0.6 A; +55 +70 °C: Derating 2%/K
supplied active power typical	14.4 W
bridging of equipment	No
efficiency in percent	81 %
power loss [W]	
<ul> <li>at rated output voltage for rated value of the output current typical</li> </ul>	3.4 W
during no-load operation maximum	0.3 W
closed-loop control	0.5 VV
	0.2 %
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical	0.2 %
relative control precision of the output voltage at load step of	2 %
resistive load 10/90/10 % typical	
setting time	
<ul> <li>load step 10 to 90% typical</li> </ul>	1 ms
<ul><li>load step 90 to 10% typical</li></ul>	1 ms
protection and monitoring	
design of the overvoltage protection	Yes, according to EN 60950-1
property of the output short-circuit proof	Yes
design of short-circuit protection	Constant current characteristic
response value current limitation typical	0.8 A
overcurrent overload capability	
when switching on	150% lout rated typ. 200 ms
• in normal operation	overload capability 150% lout rated typ. 200 ms
enduring short circuit current RMS value	i i
maximum	0.8 A
measuring point for output current	No
eafety	
galvanic isolation between input and output	Yes
galvanic isolation	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178
•	
operating resource protection class	Class II (without protective conductor)
operating resource protection class	Class II (without protective conductor)  IP20
protection class IP	Class II (without protective conductor)  IP20
protection class IP standard	IP20
protection class IP standard • for emitted interference	IP20 EN 55022 Class B
protection class IP standard • for emitted interference • for mains harmonics limitation	IP20 EN 55022 Class B not applicable
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity	IP20 EN 55022 Class B
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals	IP20 EN 55022 Class B not applicable
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability	IP20 EN 55022 Class B not applicable EN 61000-6-2
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	IP20 EN 55022 Class B not applicable EN 61000-6-2 Yes
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability	IP20 EN 55022 Class B not applicable EN 61000-6-2  Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	IP20 EN 55022 Class B not applicable EN 61000-6-2 Yes
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	P20  EN 55022 Class B  not applicable  EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval  • CSA approval	P20  EN 55022 Class B  not applicable  EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval  • CSA approval	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes
protection class IP  standard  • for emitted interference • for mains harmonics limitation • for interference immunity  standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval  • NEC Class 2	P20  EN 55022 Class B  not applicable  EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval • NEC Class 2 • SEMI F47	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval • NEC Class 2 • SEMI F47  type of certification	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273  Yes
protection class IP  standard  • for emitted interference • for mains harmonics limitation • for interference immunity  standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval • NEC Class 2 • SEMI F47  type of certification • CB-certificate	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273  Yes
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval • NEC Class 2 • SEMI F47 type of certification • CB-certificate  MTBF at 40 °C	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273  Yes
protection class IP  standard  • for emitted interference • for mains harmonics limitation • for interference immunity  standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval  • NEC Class 2 • SEMI F47  type of certification • CB-certificate  MTBF at 40 °C  standards, specifications, approvals hazardous environments	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273  Yes
protection class IP standard  • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • NEC Class 2 • SEMI F47  type of certification • CB-certificate  MTBF at 40 °C  standards, specifications, approvals hazardous environments  certificate of suitability	P20  EN 55022 Class B not applicable EN 61000-6-2  Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310) Yes Yes; according to UL1310, File E151273 Yes  Yes  4 415 040 h
protection class IP  standard  • for emitted interference • for mains harmonics limitation • for interference immunity  standards, specifications, approvals  certificate of suitability • CE marking • UL approval  • CSA approval  • EAC approval  • NEC Class 2 • SEMI F47  type of certification • CB-certificate  MTBF at 40 °C  standards, specifications, approvals hazardous environments	P20  EN 55022 Class B  not applicable EN 61000-6-2  Yes  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950, CSA C22.2 No. 60950), File E151273, NEC class 2 (acc. to UL 1310)  Yes  Yes; according to UL1310, File E151273  Yes

No
110
No
No
Yes
Yes
Yes
Yes
Yes
claration
Yes
100
107.9 kg
1.4 kg
106.5 kg
0.04 kg
0.04 kg
25 170 °C with patruples
-25 +70 °C; with natural convection
-40 +85 °C
40 +85 °C
Climate class 3K3, 5 95% no condensation
screw-type terminals
L, N: 1 screw terminal each for 0.5 2.5 mm2 single-core/finely stranded
+, -: 1 screw terminal each for 0.5 2.5 mm <sup>2</sup>
-
18 × 90 × 53 mm
18 × 130 mm
20 mm
20 mm
0 mm
0 mm
Snaps onto DIN rail EN 60715 35x7.5/15, direct mounting in different mounting positions
Yes
No
Yes
Yes
0.07 kg
Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)
Siemens provides products and solutions with industrial security functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial security concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial security measures that may be implemented, please visit https://www.siemens.com/industrialsecurity. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Security RSS Feed under

## Classifications Version Classification eClass 12 27-04-07-01 eClass 9.1 27-04-07-01 eClass 9 27-04-07-01 eClass 8 27-04-90-02 eClass 7.1 27-04-90-02 27-04-90-02 eClass 6 ETIM 9 EC002540 **ETIM** 8 EC002540 ETIM EC002540 7 **IDEA** 4 4130 UNSPSC 39-12-10-04 15

Approvals Certificates

**General Product Approval** 







Manufacturer Declara-<u>tion</u>

Declaration of Conformity



**General Product Approval** 

For use in hazardous locations







IECEx



<u>FM</u>

CCC-Ex

Marine / Shipping











**Environment** 

last modified:

3/12/2024